



Distribution Construction Standards Manual

Part 2

R – Reference

Published 30 April 2024

For application to Horizon Power Electricity Distribution
Networks

Uncontrolled document when printed. Refer Online for latest version.

Part 2 – Reference – Drawing Register

Number	Description
R1	Pole Bolt Details
R2-1	Bonding Intermediate
R3-1	Insulators
R3-2	Insulator Ties
R3-3	Armour Rods
R3-4	Vertical Clamp – Top Insulator
R4	Insulator Pin and Bolt Details
R5-1	Eyebolt Details
R5-2	Conductor Terminations
R6	Earthing
R6-1	Earthing Steel Pole
R6-2	Earthing Pole Top Switch
R6-3	Earthing Cable
R6-4	Earthing Recloser and Load Break Switch Sectionalizer
R6-5	Earthing Transformers
R7-1	Cable Cleat / Guard and Pole Top Switch Anti Climbing Guard Detail
R8-1	ABC Taps for Transformer and Cable Termination
R8-2	Lugs and Connectors Transformer and Cable
R8-3	PG Clamps Installation Instruction
R8-4	Lugs and Connectors Insulation Piercing Clamps
R8-5	Taps on HV main line connections
R8-6	Stirrup Live Line Clamp Tap Off
R9-1	Bird Flight Diverter Spacing
R10-1	Drop Out Fuse Mounting Details
R11	Flowline Fuse Mounting and Service Termination
R11-1	LV Supply to Pole Mounted Equipment
R12-1	Transformer Bare LV Fusing Details
R12-2	Transformer LV Fusing Details
R12-3	Transformer LV Isolation Details
R13-1	Pole Embedment Depth and Danger Plate
R13-2	Steel Distribution Pole Concrete Base and Belling Details
R14-1	Ground Stay
R14-2	Outrigger Stay HV and LV Tee Off
R14-3	Outrigger Stay HV or LV Termination Only / HV and LV Intermediate Only
R14-5	Aerial Stay
R16	Screw in Anchor Flow Chart
R22	MPS Substation Up to 630kVA

PROTECTED

R26-3	Class I Streetlight Cut Out Single Phase Supply for Class I Luminaires
R26-4	Class II Streetlight Cut Out Single Phase Supply for Class II Luminaires
R27	Fusing Arrangements for Street Light Columns
R29	25kVA Padmount Tx LV Distribution Board - 240V Street Feeder / Consumer Mains – 240 V Terminal Block
R33	Mini Pillar XLPE Working End
R35	Spuds Mini Pillar – 240V supply From R29 Arrangement
R36	Nulec N-Series Recloser Control Box Connection Detail
R38	Overhead Fault Indicator Solar Connection
R39	Installer Identification Tag
R40	Installation of Above Ground Cable Marker
R50	Sample Operational Label
R51	Placement of Duct Beneath Road Crossings
R52	Cable and Duct Placements on Truncations
R53	Cross Section Details of Cable Easement
R54	Placement of Duct Beneath Open Drain
R55	Cable Trench Layout Green Field Site Two Layers (1 Tx and 5 LV Cables)
R56	Cable Trench Layout Green Field Site Two Layers (1 HV Feeder, 1 Tx and LV Cables)
R57	Cable Trench Layout Green Field Site Two Layers (1 HV Feeder, 1 Tx and 2 LV Cables)
R58	Cable Trench Layout Green Field Site One Layer (1 Tx and 3 LV Cables)
R59	Cable Trench Layout Green Field Site One Layer (1 HV Feeder and LV Cables)

PROTECTED

ROUND WASHER


76 x 76 x 5 SQUARE WASHER

COIL SPRING M14 TO M24

51 x 51 x 3 SQUARE WASHER

SPRING WASHER

CUT EXCESS THREAD TO WITHIN 10mm OF NUT



FOR STEEL POLES, USE SPRING WASHER AS SHOWN ABOVE

BOLT DIMENSIONS	
DIMENSION A	DIAMETER OF POLE BOLTS
PB1 = 300mm	12mm 16mm 20mm
PB2 = 400mm	12mm 16mm 20mm
PB3 = 550mm	12mm 16mm 20mm



DISTRIBUTION CONSTRUCTION STANDARDS


POLE BOLT DETAILS

REVISION C DATE OCT 17

DRAWING No.

R1

PROTECTED



DISTRIBUTION CONSTRUCTION
STANDARDS

OPERATIONS


REFERENCE DRAWING

BONDING
INTERMEDIATE


REVISION B DATE JUNE 2011

DRAWING No. R2-1


PROTECTED
HIGH VOLTAGE (33,22,11,6.6kV)



STRAIN INSULATOR



HIGH POLLUTION
POST INSULATOR




SUPERSEDED


SUPERSEDED

RUNNING DISC ANGLE


LOW VOLTAGE




INTERMEDIATE



ANGLE UP
TO 20 DEG




INLINE STRAIN
OR ANGLE 20-45 DEG




TERMINATION

RUNNING EARTH



TERMINATION



INTERMEDIATE



SUPERSEDED

20mm BAND-IT STRAP TYPE



DISTRIBUTION CONSTRUCTION
STANDARDS

REFERENCE DRAWING

INSULATORS

REVISION
C

DATE
OCT 17


DRAWING No.

R3-1


PROTECTED

SEQUENCE OF OPERATIONS FOR HV & LV


- HALVE TIE. START WITH MIDDLE OF TIE AT BACK OF INSULATOR.
- TAKE HALF TURN AROUND INSULATOR, UNDER AND AROUND CONDUCTOR FOR ONE TURN.
 - CROSS TIE AT THE FRONT OF INSULATOR AND CONTINUE UNDER AND AROUND CONDUCTOR FOR ONE TURN.
 - CROSS TIE AT THE BACK OF INSULATOR AND CONTINUE UNDER AND AROUND CONDUCTOR FOR SIX TURNS.
 - ONE OPEN TURN.
 - FIVE TURNS.
 - ONE OPEN TURN.
 - THREE TURNS.
 - TURN ENDS OF TIE DOWN AGAINST THE CONDUCTOR.




LOW VOLTAGE
TOP TIE



LOW VOLTAGE
SIDE TIE




HIGH VOLTAGE
TOP TIE



HIGH VOLTAGE
SIDE TIE

BARE ABC 300mm OVER
CENTRE OF INSULATOR



95 & 150 mm² ABC
TOP TIE

SEQUENCE OF OPERATIONS

- HALVE TIE. START WITH MIDDLE OF TIE AT BACK OF INSULATOR.
- TAKE HALF TURN AROUND INSULATOR AND UNDER CONDUCTOR ON EACH SIDE.
 - TAKE ONE AND HALF TURNS AROUND CONDUCTOR ON EACH SIDE OF INSULATOR.
 - CROSS ENDS AROUND BACK OF INSULATOR AND RETURN TO BOTTOM OF CONDUCTOR ON EACH SIDE.
 - TAKE ONE TURN AROUND CONDUCTOR ON EACH SIDE OF INSULATOR
 - PASS ENDS OVER AND ACROSS IN FRONT OF INSULATOR CARRYING EACH END TO BOTTOM OF CONDUCTOR.
 - TAKE FIVE TURNS AROUND CONDUCTOR.
 - ONE OPEN TURN.
 - FIVE TURNS.
 - ONE OPEN TURN.
 - THREE TURNS.
 - TURN ENDS OF TIE DOWN AGAINST CONDUCTOR.

HORIZON
POWER

DISTRIBUTION CONSTRUCTION
STANDARDS


INSULATOR TIES

REVISION
C DATE
APRIL 18

DRAWING No.

R3-2

PROTECTED



ARMOUR ROD

ARMOUR RODS ARE TO BE USED ON ALL BAYS OVER 60m (WAS 80m.)



DISTRIBUTION CONSTRUCTION
STANDARDS

REVISION
D



DATE
OCT.17

ARMOUR RODS

DRAWING No.

R3-3

PROTECTED



DETAIL A - CLAMP ASSEMBLY.

CLAMP SELECTION				
CONDUCTOR TYPE	DIAMETER (mm)	CLAMP	SADDLE SIDE	REMARKS
AAAC 19/3.25	16.3	ICH0091	SMALL	
AAAC 7/4.75	14.3	ICH0091	SMALL	
AAAC 7/2.50	7.5	ICH0091	SMALL	
AAC 7/3.00	9	ICH0091	SMALL	
AAC 19/3.25	16.3	ICH0091	SMALL	
SC/AC 3/2.75	5.9	ICH0090	SMALL	NOTE 1
SC/GZ 3/2.75	5.9	ICH0090	SMALL	NOTE 1

ACCEPTABLE CONDUCTOR SIZES			
STOCK #	CLAMP TYPE	SMALL SADDLE-SIDE CONDUCTOR DIAMETER	LARGE SADDLE-SIDE CONDUCTOR DIAMETER
ICH0090	FERROUS	8.9mm - 11.3mm	12.8mm - 21.3mm
ICH0091	ALUMINIUM ALLOY	7mm - 18mm	19mm - 32mm

NOTES:

- 1) ARMOUR ROD MUST BE USED TO INCREASE CONDUCTOR DIAMETER.
- 2) TORQUE ALL BOLTS IN ASSEMBLY TO 35Nm.



DISTRIBUTION CONSTRUCTION STANDARDS


REFERENCE DRAWING

VERTICAL CLAMP-TOP INSULATOR


REVISION A DATE OCT 2018

DRAWING No. R3-4


**PROTECTED
HV INSULATOR BOLT
(STEEL CROSSARM)**



**LV INSULATOR PIN
(WOOD CROSSARM)**



**LV INSULATOR PIN
(STEEL CROSSARM)**



DISTRIBUTION CONSTRUCTION
STANDARDS




REVISION
C

DATE
OCT 17

INSULATOR PIN AND BOLT DETAILS

DRAWING No.

R4




DISTRIBUTION CONSTRUCTION
STANDARDS

REVISION	DATE
C	OCT 17

DRAWING No.

R5-1


EYEBOLT DETAILS



ALUMINIUM
CLEVIS THIMBLE

HELICAL
TERMINATION


ALUMINIUM CONDUCTOR (AAC & AAAC)
OR
STEEL CONDUCTOR (SCAC)



MALLEABLE CAST IRON
CLEVIS THIMBLE

HELICAL
TERMINATION

STEEL CONDUCTOR (SCGZ)
OR
COPPER CONDUCTOR (CU)



STRAP AND CLAMPS
SUPPLIED WITH PTS

HELICAL
TERMINATION


FOR PTS ARRANGEMENT

NOTES

REFER TO TECHNICAL BULLETIN ISSUE 2022-04 (DM 39324256) FOR PREVENTATIVE MEASURES FOR INSTALLATION OF PREFORMED DEAD-END TO AVOID CONDUCTOR SLIPPAGE.

 DISTRIBUTION CONSTRUCTION STANDARDS	REFERENCE DRAWING	REVISION D	DATE 11/01/23
	CONDUCTOR TERMINATIONS	DRAWING No R5-2	

PROTECTED



3 EXTRA ROD GUIDES REQUIRED
(POSITION TO SUIT)
SECURED WITH BAND-IT STRAPS

NOTES:

1. 20mm WIDE BAND-IT STRAPS ON RAYCHEM BRACKET, POLE ROD GUIDES AND LV ANGLE INSULATOR BRACKET. 12mm WIDE BAND-IT STRAPS ON CABLE GUARDS.
2. AN APPROVED EARTHING BRAID MUST BE FITTED TO BOND THE OPERATING HANDLE TO THE HANDLE FRAME.
3. 12mm WIDE BAND-IT STRAPS FITTED WITH SADDLES TO FIX EQUIPMENT DOWN EARTHS TO POLE. TO BE SPACE APPROXIMATELY 500mm APART.
4. INSTALLED EARTHING RESISTANCE SHALL NOT EXCEED THE MAXIMUM DESIGN VALUE STATED IN THE DESIGN PACKAGE.

R7 - STANDARD CABLE GUARD



DISTRIBUTION CONSTRUCTION
STANDARDS


EARTHING

REVISION D	DATE OCT 17
---------------	----------------

DRAWING No.

R6

PROTECTED



NOTE:

- 1) RUNNING EARTH NOT TO BE CONNECTED TO POLE ON TRANSFORMER INSTALLATIONS WITH SINGLE PHASE AND RUNNING EARTH.
2. INSTALLED EARTHING RESISTANCE SHALL NOT EXCEED THE MAXIMUM VALUE STATED IN THE DESIGN PACKAGE.



DISTRIBUTION CONSTRUCTION STANDARDS


EARTHING STEEL POLE

REVISION A	DATE OCT 17
---------------	----------------

DRAWING No.


R6-1

PROTECTED



NOTES:

1. EARTH WIRE SHALL BE CONTINUOUS.
2. 12mm WIDE BAND-IT STRAPS FITTED WITH SADDLES TO FIX EQUIPMENT DOWN EARTHS TO POLE. TO BE SPACE APPROXIMATELY 500mm APART



HORIZON
POWER

DISTRIBUTION CONSTRUCTION
STANDARDS



EARTHING
POLE TOP SWITCH

REVISION A	DATE OCT 17
---------------	----------------

DRAWING No.

R6-2

PROTECTED



REFER R6 FOR EARTH RESISTANCE REQUIREMENTS



DISTRIBUTION CONSTRUCTION STANDARDS


REVISION	DATE
D	OCT 17

EARTHING CABLE

DRAWING No.

R6-3

PROTECTED



DISTRIBUTION CONSTRUCTION STANDARDS


EARTHING
RECLOSER AND LOAD BREAK SWITCH
SECTIONALISER

REVISION A	DATE APRIL 18
---------------	------------------

DRAWING No.

R6-4

PROTECTED



70mm² DOWN
EARTH (R6)

N

R12

PH

FUSE HOLDER

ABC SPLICE CUT TO
LENGTH AND CRIMPED
TO ABC

R1

EARTH POINT

R13

R6

REFER R6 FOR EARTH
RESISTANCE REQUIREMENTS




DISTRIBUTION CONSTRUCTION
STANDARDS

EARTHING
TRANSFORMERS

REVISION F	DATE APRIL 18
---------------	------------------

DRAWING No.
R6-5

PROTECTED



NOTES:

1. DRILL AND TAP METHOD PREFERRED TO BANDIT STRAPS REFERED TO IN NOTES BELOW.
2. CABLE CLEATS SECURED WITH 12mm BANDIT STRAPS MINIMUM OF 2 REQUIRED.
3. CABLE GUARD SECURED WITH 12mm BANDIT STRAPS MINIMUM OF 2 REQUIRED. MINIMUM GAP POSSIBLE BETWEEN F.G.L. AND GUARD SHALL BE MAINTAINED.
4. ANTICLIMBING GUARD SECURED WITH 12mm BANDIT STRAPS MIN 2 REQUIRED.
5. IN ALL SECTIONS WHERE POLES ARE DRAWN WITH URD CABLES ON THEM THE FOLLOWING WILL APPLY FOR THE CABLE INSTALLATION.
 - ALL CABLES SHALL BE INSTALLED ON THE OPPOSITE SIDE OF THE POLE TO ONCOMING TRAFFIC.
 - SHOULD POINT ABOVE BE IMPRACTICAL, THE CABLES MAY BE INSTALLED ON THE FOOTPATH SIDE, (BETWEEN POLE AND PROPERTY BOUNDARY)
 - IF THE CONNECTION POINT AT THE POLE TOP IS ON THE OPPOSITE SIDE OF THE INSTALLED CABLE, THEN THE CABLE MUST BE ROLLED AROUND THE POLE ON THE FOOTPATH SIDE (BETWEEN POLE AND PROPERTY BOUNDARY) UP TO THE CONNECTION.
 - FOR POLE TOP SWITCH POLES THE CABLE MUST BE INSTALLED ON THE FOOTPATH SIDE (BETWEEN POLE AND PROPERTY BOUNDARY) THEN ROLLED AS HIGH UP AS POSSIBLE TO THE SIDE OF THE CONNECTION.



DISTRIBUTION CONSTRUCTION STANDARDS

CABLE CLEAT / GUARD AND
POLE TOP SWITCH
ANTI CLIMBING GUARD DETAIL



REVISION B	DATE APRIL 18
---------------	------------------

DRAWING No.


R7-1

PROTECTED



1. LINE TAPS TO DROPOUT FUSE OR CABLE SURGE ARRESTOR



2. LIVE STIRRUP TO SINGLE PHASE TRANSFORMER



3. DROPOUT FUSE TO TRANSFORMER WITH SURGE ARRESTOR



NOTE:

1. CLEAN OFF PAINT TO ENSURE GOOD ELECTRICAL CONTACT BEFORE APPLYING CONDUCTIVE GREASE.
2. WHERE THE INSULATED SPLICE CRIMP IS NOT USED FOR LINE TAPS, A 20mm LENGTH OF INSULATION MUST BE REMOVED BEHIND THE INSULATED LUG TO ALLOW MOISTURE TO DRAIN. SEE R8/2 FOR PG CLAMP APPLICATION.
3. REFER TO R8-6 IF LIVE LINE CLAMP AND STIRRUP IS USED.



DISTRIBUTION CONSTRUCTION STANDARDS


ABC TAPS FOR TRANSFORMER AND CABLE TERMINATION

REVISION	DATE
D	15/04/2021

DRAWING No.

R8-1

PROTECTED



DISTRIBUTION CONSTRUCTION STANDARDS

LUGS AND CONNECTORS
TRANSFORMER AND CABLE

REVISION E	DATE APRIL 18
---------------	------------------


DRAWING No.

R8-2

PROTECTED



SMALL COPPER PG CLAMP FOR
UP TO 70mm sq COPPER CONDUCTOR
INCLUDING Cu DOWN EARTH JOINS



(NOTE 1)

PARALLEL GROOVE CLAMPS

STEP 1

WIRE BRUSH SURFACE OF CONDUCTOR AND JAWS OF CLAMP. THEN IMMEDIATELY APPLY ALUMINIUM JOINTING COMPOUND. STOCK No. PG 0002

STEP 2

FIT CLAMP AND TIGHTEN BOLTS SECURELY.
IF COPPER TO ALUMINIUM THEN ALUMINIUM CONDUCTOR TO BE ABOVE THE COPPER

STEP 3

IN AREAS OF HIGH POLLUTION
(TYPICALLY WITHIN 5 Kms OF COAST)
APPLY GREASE TO COVER ALL PARTS OF JOINT.
USE SHELL MP2 - STOCK No PG0125.

IN EXTREMELY CORROSIVE ENVIRONMENTS WHERE THIS HAS PROVEN INADEQUATE, THEN APPLY 510 DENSO TAPE OVER GREASE AND JOINT TO EXCLUDE ALL MOISTURE - STOCK No HTH0001

REUSE OF PG CLAMPS

DO NOT REUSE PG CLAMPS WHICH HAVE BEEN SUBJECTED TO HEAVY FAULT CONDITIONS AND EXCESSIVE CORROSION

CONTACT GROOVES OF THE PG CONDUCTOR INTERFACE MUST BE THOROUGHLY CLEANED TO BRING THE SURFACE BACK TO "AS NEW" CONDITION

APPLY CONTACT PROTECTION GREASE TO REINSTATE ENVIRONMENTAL PROTECTION AT THE INTERFACE

NOTES:

1. DOUBLE PG CLAMPS MUST BE USED ON ALL NEUTRAL CONNECTIONS.

HORIZON
POWER

DISTRIBUTION CONSTRUCTION
STANDARDS


PG CLAMPS
INSTALLATION INSTRUCTION

REVISION DATE
E OCT 17


DRAWING No.

R8-3

PROTECTED



ABC TO SERVICE 95/35-6 & 150/35-6



LV MAINS IPC - ABC TO ABC



DISTRIBUTION CONSTRUCTION
STANDARDS

LUGS AND CONNECTORS
INSULATION PIERCING CLAMPS


REVISION C	DATE APRIL 18
---------------	------------------

DRAWING No.


R8-4

PROTECTED


PREFERRED WHERE POSSIBLE TO USE EXISTING BARE CONDUCTOR WITH ONE CONNECTOR.



ALTERNATIVELY USE 150mm² LV ABC CONDUCTOR.





DETAIL A



SUPPORT TAP USING TIE WIRE - 4 WRAPS, TWITCH ENDS WITH PLIERS AND FOLD BACK. CABLE OR ZIP TIES NOT TO BE USED

CABLE TERMINATION

- USE 95mm² LVABC FOR 35/50/95mm² CABLES.
- USE 150mm² LVABC FOR ALL OTHER CABLES.
i.e. 185/240/400mm² CABLES



NOTES:-
1. REFER TO DETAIL A ON R8-1.
2. REFER TO DETAIL B ON R8-1.



DISTRIBUTION CONSTRUCTION STANDARDS


TAPS ON HV MAIN LINE CONNECTIONS

REVISION A DATE 15/04/2021

DRAWING No.

R8-5


AAC/AAAC, COPPER, SCGZ CONDUCTORS
PROTECTED



COPPER
STIRRUP

LIVE LINE CLAMP

3/2 75 STEEL CONDUCTOR




PG CLAMP

STAINLESS STEEL
STIRRUP

LIVE LINE CLAMP

SPLICE

7/160 SC/GZ CONDUCTOR



PG CLAMP

STAINLESS STEEL
STIRRUP

LIVE LINE CLAMP

HORIZON
POWER

DISTRIBUTION CONSTRUCTION
STANDARDS

STIRRUP LIVE LINE CLAMP
TAP OFF

REVISION	DATE
A	12/03/2021


DRAWING No.

R8-6


PROTECTED

GENERIC BIRD DIVERTER LOCATION


THREE PHASES



TWO PHASES



SINGLE PHASE



LARGER BIRDS - ANTI-SWAN



NOTES:-

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. THIS DRAWING IS SUGGESTED INSTALLATION SPACING ONLY.
3. SEE CN79 TO SELECT CORRECT BIRD DIRECTORS FOR CONDUCTOR DIAMETERS.
4. USE ANTI-SWAN TYPE APPLICATION FOR PELICAN/SWAN AS REQUIRED.



DISTRIBUTION CONSTRUCTION
STANDARDS


BIRD FLIGHT DIVERTER SPACING

REVISION	DATE
A	23/04/2024


DRAWING No.

R9-1


POLE MOUNTED




PROTECTED CROSS-ARM MOUNTED




TERMINATION POLE TOP SWITCH





EXTENTION ARM MOUNTED



ALTERNATE CROSS-ARM MOUNTING



STANDARD MOUNTING



MOUNTING VARIATIONS ON EXISTING STRUCTURES FOR FITTING & BARREL SWING CLEARANCE

- NOTES:
 1. STANDARD 170kV BIL EXPULSION DROPOUT FUSE UP TO 33kV WITH STANDOFF INSULATOR FOR ALL INSTALLATIONS.



DISTRIBUTION CONSTRUCTION STANDARDS



DROPOUT FUSE MOUNTING DETAILS WITH MOUNTING BRACKET

REVISION	DATE
E	06/11/2020

DRAWING No.

R10-1

PROTECTED



NOTES:

1. SERVICE WIRE TO BE INSTALLED AT A SAFE DISTANCE FROM THE POLE WITH ENOUGH CLEARANCE TO NOT TOUCH THE POLE.
2. FLOWLINE BOX WHEN MOUNTED ON THE SAME SIDE OF THE CROSSARM THAT THE SERVICE IS ATTACHED, WILL PROVIDE BETTER CLEARANCE.
3. WHEN THERE IS INADEQUATE CLEARANCE A RISK ASSESSMENT IS REQUIRED AND ADDITIONAL INSULATION OR SECURING METHOD MUST BE APPLIED.
4. ALL SERVICES MUST BE FUSED



DISTRIBUTION CONSTRUCTION STANDARDS


FLOWLINE FUSE MOUNTING AND SERVICE TERMINATION

REVISION E	DATE APRIL 18
---------------	------------------


DRAWING No.

R11


PROTECTED




LV AERIAL CONNECTION SIDE VIEW



LV ABC CONNECTION SIDE VIEW



LV TRANSFORMER CONNECTION SIDE VIEW



LV UMS CONNECTION SIDE VIEW

NOTE 1
THIS DRAWING SHOWS LV SUPPLY ARRANGMENT ONLY.
REFER TO RELEVANT POLE MOUNTED EQUIPMENT FOR
DETAILS OF CONSTRUCTION



DISTRIBUTION CONSTRUCTION
STANDARDS


LV SUPPLY
TO POLE MOUNTED EQUIPMENT

REVISION	DATE
B	APRIL 18


DRAWING No.

R11-1

PROTECTED



25 AND 63kVA TO BARE CONDUCTOR



100 AND 200kVA TO BARE CONDUCTOR





DISTRIBUTION CONSTRUCTION STANDARDS

REVISION	DATE
D	01/10/17

TRANSFORMER BARE LV FUSING DETAILS

DRAWING No.
R12-1

PROTECTED




315kVA TO ABC OR LV BARE
REFER TO R12-3
FOR OPTIONS

NOTES:

1. ALTERNATIVE POSITION FOR BRACKET IF CABLE CLEARANCE CANNOT BE OBTAINED
2. FUSES PREFERABLY ON ROADSIDE

100 and 200kVA TO ABC



SINGLE PHASE 10 AND 25kVA




DISTRIBUTION CONSTRUCTION
STANDARDS

TRANSFORMER LV
FUSING DETAILS

REVISION D	DATE OCT 17
---------------	----------------


DRAWING No.
R12-2

OPTION 1





PROTECTED



1 PHASE ONLY
SHOWN FOR CLARITY
SINGLE LINE REPRESENTATION





OPTION 2



OPTION 3



OPTION 4



DISTRIBUTION CONSTRUCTION
STANDARDS


OPERATIONS

REFERENCE DRAWING

TRANSFORMER LV
ISOLATION DETAILS

REVISION	DATE
B	JUNE 2011

DRAWING No.
R12-3



NOTE:

1. STANDARD POLE EMBEDMENT DEPTH

POLE LENGTH	EMBEDMENT DEPTH
9.5m	1.55m
11.0m	1.70m
12.5m	1.85m
14.0m	2.00m

EXAMPLE 9.5m POLE

$$\begin{aligned}
 E &= (PL + 6.0) / 10 \\
 &= (9.5 + 6.0) / 10 \\
 &= (15.5) / 10 \\
 &= 1.55m
 \end{aligned}$$

2. BACKFILL SHOULD BE MECHANICALLY COMPACTED IN 300mm LAYERS AND IN STEPS OF 150mm LAYERS IF HAND COMPACTED.
3. REFER TO R13-2 WHERE CONCRETE BACKFILL IS REQUIRED TO ENHANCE POLE FOUNDATION STRENGTH. SCENARIOS INCLUDE:
 - A. INSTALLATION IN CYCLONIC REGION C & D (MANDATORY)
 - B. INSTALLATION IN AREAS WITH POOR SOIL EVALUATION BY ENGINEERED ASSESSMENT.
 - C. SELF SUPPORTIVE POLE DETERMINED BY ENGINEERED ASSESSMENT.



DISTRIBUTION CONSTRUCTION STANDARDS

POLE EMBEDMENT DEPTH AND DANGER PLATE



REVISION	DATE
C	22/02/2021

DRAWING No.
R13-1

PROTECTED

CONCRETE BASE AND BELLING DETAILS:

1. CONCRETE BASE AND BELLING MUST BE USED FOR CYCLONIC AREAS (AS/NZS 1170.2 REGIONS C AND D).
2. A FLEXI CONDUIT SHALL BE FITTED TO PROVIDE ACCESS FOR CABLE INSTALLATION TO THE POLE & CABLE REMOVAL FROM THE POLE.
3. CONCRETE MIX SHALL:
 - A. HAVE A MINIMUM STRENGTH OF 25MPA (N25 CONCRETE).
 - B. HAVE A 20mm NOMINAL AGGREGATE.
 - C. HAVE A SLUMP OF 80mm.
 - D. WHEN MIXED ON SITE BASED ON THE FOLLOWING RATIO BETWEEN CEMENT, CLEAN SAND, AGGREGATE AND WATER: 1:2:3:1.
 - E. BE MECHANICALLY VIBRATED TO REMOVE TRAPPED AIR POCKETS.
4. UNLESS OTHERWISE SPECIFIED IN THE DESIGN TO CATER FOR SPECIAL CIRCUMSTANCES, IT SHALL HAVE:
 - A. DEPTH OF 800mm.
 - B. DIAMETERS OF 600mm AND 900mm RESPECTIVELY FOR SANDY SOIL AND CLAY.



BACKFILL
REFER TO R13-1 NOTE 2




DISTRIBUTION CONSTRUCTION STANDARDS

STEEL DISTRIBUTION POLE
CONCRETE BASE AND BELLING DETAILS


REVISION	DATE
D	22/02/2021

DRAWING No.
R13-2

PROTECTED



INSTALLATION ANGLES AND TENSIONS OF STAYS					
ANGLE a (DEGREES)	ANGLE b (DEGREES)	ANGLE c (DEGREES)	A= (LENGTH)	C= (LENGTH)	C (TENSION)
90	60	30	Bx1.73	Bx2	SUM OF LINE LOAD x 1.15
90	45	45	B	Bx1.41	SUM OF LINE LOAD x 1.41
90	30	60	Bx0.57	Bx1.15	SUM OF LINE LOAD x 2



A = POSITION OF STAY ROD FROM BASE OF POLE
 B = HEIGHT OF STAY ATTACHMENT ABOVE GROUND
 C = LENGTH OF STAY WIRE

NOTE:

1. IF THE STAY WIRE PASSES THROUGH L.V. MAINS THEN THE L.V. MAINS MUST BE CONSTRUCTED ON A 2100mm CROSSARM AND COVERED IN INSULATING MATERIAL
2. STAY INSULATOR CAN BE ELIMINATED ONLY IF RISK OF EPR ZONE EXTENSION HAS BEEN ASSESSED.




DISTRIBUTION CONSTRUCTION STANDARDS

REFERENCE DRAWING

GROUND STAY

REVISION B	DATE NOV 18
---------------	----------------

DRAWING No.
R14-1



DISTRIBUTION CONSTRUCTION STANDARDS


OPERATIONS

REFERENCE DRAWING

OUTRIGGER STAY
HV AND LV TEE-OFF

REVISION	DATE
B	MARCH 14

DRAWING No.
R14-2



NOTES:

1. IF THE STAY WIRE PASSES THROUGH L.V. MAINS THEN THE L.V. MAINS MUST BE CONSTRUCTED ON A 2100mm CROSSARM AND COVERED IN INSULATING MATERIAL
2. CLAMP SADDLE MOUNT (SI # FM0900).
3. TO BE USED ONLY WHERE GROUND STAY CANNOT BE USED.
4. STAY ANGLE IF VARIED MUST BE AS PER DESIGN.




DISTRIBUTION CONSTRUCTION STANDARDS

OUTRIGGER STAY
HV OR LV TERMINATION ONLY
HV AND LV INTERMEDIATE ONLY

REVISION	DATE
C	NOV 18

DRAWING No.
R14-3

PROTECTED



NOTES:

1. STAY INSULATOR/S MUST BE FITTED 3.0m FROM POLE. STAY MAY REQUIRE TWO INSULATORS IF OVER CONDUCTOR AT BOTH ENDS.



DISTRIBUTION CONSTRUCTION STANDARDS


REVISION	DATE
C	20/01/2021

DRAWING No.

AERIAL STAY

R14-5

PROTECTED



DISTRIBUTION CONSTRUCTION
STANDARDS

OPERATIONS



REFERENCE DRAWING

SCREW IN ANCHOR
FLOW CHART

REVISION B	DATE JUNE 2011
---------------	-------------------

DRAWING No. R16

PROTECTED




CABLE TO FUSE SWITCH
(REF R25)



5 x 400 AMP COVERS SUPPLIED WITH MPS



630 AMP COVER WITH 600 AMP LINKS - OPTIONAL



2 X 630 COVERS FIXED TOGETHER WITH
600 AMP LINKS
1200 AMP ARRANGEMENT - OPTIONAL

NOTES:

1. MPS COMES COMPLETE WITH TRANSFORMER AND 5 x LV SWITCHES INCLUDING 630 AMP BASES.
2. CABLE SUPPLIED WITH MPS TRANSFORMER RANGE - 160, 315 AND 630 kVA



DISTRIBUTION CONSTRUCTION
STANDARDS


REVISION A	DATE JUNE 18
---------------	-----------------

MPS SUBSTATION
UP TO 630 kVA


DRAWING No.
R22

NOTE:

1. LST 10A FUSE (STOCK CODE: GF1300) MUST BE INSTALLED FOR ALL INSTALLATIONS.
2. CONNECT EARTH WIRE TO MOUNTING BRACKET USING TERMINAL LUG (FL0163) AND M6 SCREW (AB2820).
3. CONNECT 6mm EARTH WIRE (EE1364) TO POLE MOUNTING BRACKET FROM EARTH TERMINAL.
4. MEN BRIDGE OR 6mm EARTH WIRE (EE1364) LOOP.
5. IF EXISTING LUMINAIRE CABLE IS TPS TYPE OR OLDER, THEN INSTALLATION REMAINS AS CLASS I. OTHERWISE REFER TO R26-4 FOR CLASS II INSTALLATION.
6. LUMINAIRE CABLE SHEATH MUST ENTER CUT-OUT HOUSING AS SHOWN.



CLASS I
INSTALLATION



DISTRIBUTION CONSTRUCTION
STANDARDS


CLASS I STREETLIGHT CUTOUT
SINGLE PHASE SUPPLY
FOR CLASS I LUMINIARES

REVISION	DATE
D	23/07/2020

DRAWING No.


R26-3

PROTECTED



FROM A LOOPED SERVICE

CUTOFF ANY PORTION OF SCREW THREAD PROTRUDING BEYOND SECOND NUT.



FROM A MINI PILLAR

NOTES FOR PILLAR CONNECTIONS.

1. DISTRIBUTE LIGHTING LOAD ACROSS THE PHASES WITHIN THE DEVELOPMENT.
2. DESIGNER TO USE EARTH FAULT LOOP CALCULATOR DM# 11672288 TO DETERMINE REDSPOT FUSE SIZE.
3. REFER TO U9-1 FOR UNI PILLAR INSTALLATION AND U8-2 FOR MINI PILLAR INSTALLATION.
4. REFER TO DETAILS IN DRAWING R26 SERIES.



DISTRIBUTION CONSTRUCTION STANDARDS


FUSING ARRANGEMENTS FOR STREETLIGHT COLUMNS

REVISION	DATE
E	04/09/2020

DRAWING No.

R27

PROTECTED




240V CONFIGURATION

12.7kV OR 22kV 25kVA/240 - 480V TRANSFORMER

 DISTRIBUTION CONSTRUCTION STANDARDS OPERATIONS	REFERENCE DRAWING	REVISION A	DATE 15/09/2020
	25kVA PADMOUNT TX LV DISTR BOARD 240V STREET FEEDER/CONSUMER MAINS 240V TERMINAL BLOCK	DRAWING No. R29	

PROTECTED



NOTES:

1. MINI PILLAR ENCLOSED WORKING END, LID OF PILLAR TO BE PAINTED WHITE.
2. TWO LAYERS OF HEATSHRINK REQUIRED AT WORKING END.



DISTRIBUTION CONSTRUCTION STANDARDS



MINI PILLAR
LV FEEDER CABLE WORKING END

REVISION	DATE
D	04/09/2020

DRAWING No.

R33

PROTECTED



NOTES:

1. MAXIMUM CABLE SIZE 35mm²



DISTRIBUTION CONSTRUCTION STANDARDS


OPERATIONS

REFERENCE DRAWING

SPUDS MINI PILLAR
240V SUPPLY FROM R29
ARRANGEMENT

REVISION	DATE
D	15/09/2020

DRAWING No.
R35



NOTES:

1. FOR DOUBLE SKIN OR PAINTED ENCLOSURES AN EARTH LEAD IS REQUIRED FOR THE SURGE ARRESTOR.
2. REFER TO DISTRIBUTION COMMISSIONING TEST SHEET OF VERMIN PROOFING - POLE MOUNTED RECLOSER/ISOLATOR



DISTRIBUTION CONSTRUCTION STANDARDS

OPERATIONS


REFERENCE DRAWING

NULEC N-SERIES RECLOSER CONTROL BOX CONNECTION DETAIL

REVISION	DATE
D	MARCH 14

DRAWING No.
R36

PROTECTED



DISTRIBUTION CONSTRUCTION STANDARDS


OPERATIONS

REFERENCE DRAWING

OVERHEAD FAULT INDICATOR
SOLAR CONNECTION

REVISION B	DATE JUNE 2011
---------------	-------------------

DRAWING No.
R38



NOTES:

1. INSTALLER TO MARK TAG AS DETAILED WITH SUITABLE PUNCH SET
2. ONE TAG IS REQUIRED WHERE A 3 PHASE SET IS INSTALLED

 DISTRIBUTION CONSTRUCTION STANDARDS	REFERENCE DRAWING	REVISION C	DATE MAY 18
	INSTALLER IDENTIFICATION TAG	DRAWING No. R39	




PROTECTED

REMOVAL TOOL


FRONT VIEW
STOCK CODE CR0332

BACK VIEW

DANGER LABEL



INSTALLATION TOOL
STOCK CODE CR 0330



NOTES:

- 1. REMOVAL TOOL TO BE ORDERED FROM SUPPLIER AS NEEDED



DISTRIBUTION CONSTRUCTION
STANDARDS

REFERENCE DRAWING

INSTALLATION OF
ABOVE GROUND CABLE MARKER

REVISION
C

DATE
MAY 18

DRAWING No.

R40

DANGER!!

EQUIPMENT IS OPERATIONAL

TREAT AS ENERGISED

LABEL SPECIFICATIONS

- ALUMINIUM, SELF ADHESIVE, WEATHERPROOF.
- DIMENSIONS : 100mm (WIDTH) x 80mm (DEPTH).
- "DANGER" TO APPEAR IN RED, OTHER TEXT IN BLACK.
- MOUNTED IN PROMINENT POSITION ON EQUIPMENT E.G. SIDE OF MINI AND UNIVERSAL PILLAR OR FRONT DOOR OF SUBSTATION.
- OTHER TAGS AVAILABLE:
 - DANGER : OTHER END NOT TERMINATED
 - DO NOT ENERGISE




DISTRIBUTION CONSTRUCTION
STANDARDS

REVISION	DATE
B	MAY 18


DRAWING No.

R50

SAMPLE OPERATIONAL LABEL



CONDUIT INSTALLATION REQUIREMENTS FOR HV & LV CABLES
PROTECT CABLES BETWEEN EDGE OF ALIGNMENT AND END OF CONDUIT WITH PROTECTION SLABS



CONDUIT INSTALLATION REQUIREMENTS FOR SERVICE & STREET LIGHT CABLES
CONDUIT SHALL BE INSTALLED TO EDGE OF CABLE ALIGNMENT

NOTES:

1. REFER TO HORIZON POWER UNDERGROUND CABLE INSTALLATION MANUAL FOR SPECIFIC REQUIREMENTS.




DISTRIBUTION CONSTRUCTION STANDARDS

**PLACEMENT OF DUCT
 BENEATH ROAD CROSSINGS**

REVISION B	DATE MAY 18
----------------------	-----------------------

DRAWING No.
R51



NOTE:

THE DUCT SHALL BE INSTALLED FROM EDGE TO EDGE OF THE CABLE ALIGNMENT.




DISTRIBUTION CONSTRUCTION STANDARDS

CABLE AND DUCT PLACEMENTS ON TRUNCATIONS

REVISION B	DATE MAY 18
----------------------	-----------------------

DRAWING No.
R52

PROTECTED



NOTES:

1. WHERE DUCT IS HEAVY DUTY AND MEETS THE REQUIREMENT OF CATEGORY A (AS DEFINED BY AS/NZS 3000 WIRING RULES), CONCRETE ENCASEMENT IS NOT REQUIRED.
2. CONDUITS SHALL BE CENTRED IN EASEMENT.
3. ENCASEMENT THICKNESS "T" SHALL BE AT LEAST 75mm OR 75% OF THE LARGEST CONDUIT NOMINAL DIAMETER, WHICHEVER IS GREATER.
4. ENCASEMENT THICKNESS "T" SHALL BE AT MOST 150mm OR 200% OF THE LARGEST CONDUIT NOMINAL DIAMETER, WHICHEVER IS SMALLER.



DISTRIBUTION CONSTRUCTION STANDARDS

CROSS SECTION DETAILS OF CABLE EASEMENT

REVISION B **DATE MAY 18**

DRAWING No.

R53

ROADWAY

PROTECTED

LOT

CABLE

PUBLIC OPEN SPACE

DUCT WHERE CABLE
CROSSES OPEN DRAINS

OPEN DRAIN


PUBLIC OPEN SPACE

ROADWAY

LOT

UNDERGROUND
POWER ALIGNMENT

(NOTES 4 & 5)



CONCRETE ENCASEMENT DETAIL

NOTES:

1. DUCTS SHALL BE CONCRETE ENCASED AND HAVE A MINIMUM COVER OF 850mm BELOW THE BOTTOM OF WATER COURSE OR OPEN DRAIN.
2. DUCTS SHALL EXTEND TO THE PROPERTY BOUNDARY EITHER SIDE OF THE WATER COURSE OR OPEN DRAIN.
3. WHERE DIRECTIONAL DRILLING IS USED, CONCRETE ENCASEMENT IS NOT REQUIRED, DEPTH SHALL BE BETWEEN 900mm AND 1500mm AND DUCTS SHALL EXTEND 1500mm BEYOND EXTENT OF WATER COURSE EACH SIDE.
4. ENCASEMENT THICKNESS "T" SHALL BE AT LEAST 75mm OR 75% OF THE LARGEST CONDUIT NOMINAL DIAMETER, WHICHEVER IS GREATER.
5. ENCASEMENT THICKNESS "T" SHALL BE AT MOST 150mm OR 200% OF THE LARGEST CONDUIT NOMINAL DIAMETER, WHICHEVER IS SMALLER.




DISTRIBUTION CONSTRUCTION
STANDARDS

PLACEMENT OF DUCT BENEATH
OPEN DRAIN

REVISION A	DATE 21/08/15
---------------	------------------

DRAWING No. R54

PROTECTED



● LV CABLE

⊗ 35mm² OR 50mm² HV CABLE (TRANSFORMER)

NOTES:

1. LV CABLES SHALL BE ON THE TOP LAYER WITH THIS LAYER CONSISTING OF A MAXIMUM OF 5 LV CABLES.
2. LV CABLE JOINTS ARE APPROXIMATELY $\phi 170\text{mm}$.
3. LV CABLE JOINTS SHALL BE INSTALLED ABOVE OTHER LV CABLES.
4. LV CABLE JOINTS SHALL BE INSTALLED AT STAGGERED LOCATIONS.
5. LAYOUT OF HV CABLES SHALL START FROM THE ROAD SIDE OF THE TRENCH.
6. THE MINIMUM DEPTH OF COVER OF CABLES SHALL BE 850mm. THE DEPTH OF COVER OF CABLES IN A NOMINAL CABLE ALIGNMENT SHALL BE INCREASED AS REQUIRED SO THAT THE CABLE JOINTS ALSO HAVE THE NECESSARY DEPTH OF COVER.



DISTRIBUTION CONSTRUCTION STANDARDS

CABLE TRENCH LAYOUT
GREEN FIELD SITE
TWO LAYERS (1 Tx AND 5 LV CABLES)

REVISION B DATE MAY 18

DRAWING No. R55

PROTECTED

500

PROPERTY BOUNDARY

ROAD RESERVE

CABLE TRENCH

425

850

MARKER TAPE LEVEL

25

TRANSFORMER AND LV CABLES INCLUDING STREET LIGHT AND SERVICE CABLES.

100

200

HV CABLE (FEEDER)

150

BEDDING

● LV CABLE

⊗ 35mm² OR 50mm² HV CABLE (TRANSFORMER)

⊠ HV CABLE (FEEDER)

NOTES:

1. LV CABLES SHALL BE ON THE TOP LAYER WITH THIS LAYER CONSISTING OF NO MORE THAN 2 LV CABLES AND 1 X 35mm² HV CABLE.
2. LV CABLE JOINTS ARE APPROXIMATELY ϕ 170mm.
3. LV CABLE JOINTS SHALL BE INSTALLED ABOVE OTHER LV CABLES.
4. LV CABLE JOINTS SHALL BE INSTALLED AT STAGGERED LOCATIONS.
5. LAYOUT OF HV CABLES SHALL START FROM THE ROAD SIDE OF THE TRENCH.
6. THE MINIMUM DEPTH OF COVER OF CABLES SHALL BE 850mm. THE DEPTH OF COVER OF CABLES IN A NOMINAL CABLE ALIGNMENT SHALL BE INCREASED AS REQUIRED SO THAT THE CABLE JOINTS ALSO HAVE THE NECESSARY DEPTH OF COVER.



DISTRIBUTION CONSTRUCTION STANDARDS

REVISION
B


DATE
MAY 18

CABLE TRENCH LAYOUT
GREEN FIELD SITE
TWO LAYERS (1 HV FEEDER, 1 Tx & LV CABLES)

DRAWING No.

R56

PROTECTED



LV CABLE



35mm² OR 50mm² HV CABLE (TRANSFORMER)



HV CABLE (FEEDER)

NOTES:

1. LV CABLES SHALL BE ON THE TOP LAYER WITH THIS LAYER CONSISTING OF NO MORE THAN 2 LV CABLES.
2. LV CABLE JOINTS ARE APPROXIMATELY ϕ 170mm.
3. LAYOUT OF THE HV CABLES SHALL START FROM THE ROAD SIDE OF THE TRENCH.
4. IF THE 35mm² HV CABLE IS NOT ON THE BOTTOM LAYER IT SHALL BE NEAREST TO THE ROADSIDE.
5. THE MINIMUM DEPTH OF COVER OF CABLES SHALL BE 850mm. THE DEPTH OF COVER OF CABLES IN A NOMINAL CABLE ALIGNMENT SHALL BE INCREASED AS REQUIRED SO THAT THE CABLE JOINTS ALSO HAVE THE NECESSARY DEPTH OF COVER.



DISTRIBUTION CONSTRUCTION STANDARDS

REVISION
B


DATE
MAY 18

**CABLE TRENCH LAYOUT
GREEN FIELD SITE
TWO LAYERS (1 HV FEEDER, 1 Tx & 2 LV CABLES)**

DRAWING No.

R57

PROTECTED



● LV CABLE

⊗ 35mm² OR 50mm² HV CABLE (TRANSFORMER)

NOTES:

1. FOR A ONE LAYER CABLE TRENCH NO MORE THAN 4 X 185mm² OR 3 X 240mm² LV CABLES AND 1 X 35mm² HV CABLE CAN BE INSTALLED.
2. LV CABLE JOINTS ARE APPROXIMATELY ϕ 170mm.
3. LV CABLE JOINTS SHALL BE INSTALLED ABOVE OTHER LV CABLES.
4. LV CABLE JOINTS SHALL BE INSTALLED AT STAGGERED LOCATIONS.
5. LAYOUT OF HV CABLES SHALL START FROM THE ROAD SIDE OF THE TRENCH.
6. THE MINIMUM DEPTH OF COVER OF CABLES SHALL BE 850mm. THE DEPTH OF COVER OF CABLES IN A NOMINAL CABLE ALIGNMENT SHALL BE INCREASED AS REQUIRED SO THAT THE CABLE JOINTS ALSO HAVE THE NECESSARY DEPTH OF COVER.




DISTRIBUTION CONSTRUCTION
STANDARDS

REVISION B DATE MAY 18

CABLE TRENCH LAYOUT
GREEN FIELD SITE
ONE LAYER (1 Tx AND 3 LV CABLES)

DRAWING No.
R58

PROTECTED



● LV CABLE

⊗ HV CABLE (FEEDER)

NOTES:

1. LV CABLE JOINTS ARE APPROXIMATELY $\phi 170\text{mm}$.
2. LV CABLE JOINTS SHALL BE INSTALLED ABOVE OTHER LV CABLES.
3. LV CABLE JOINTS SHALL BE INSTALLED AT STAGGERED LOCATIONS.
4. LAYOUT OF HV CABLES SHALL START FROM THE ROAD SIDE OF THE TRENCH.
5. THE MINIMUM DEPTH OF COVER OF CABLES SHALL BE 850mm. THE DEPTH OF COVER OF CABLES IN A NOMINAL CABLE ALIGNMENT SHALL BE INCREASED AS REQUIRED SO THAT THE CABLE JOINTS ALSO HAVE THE NECESSARY DEPTH OF COVER.



DISTRIBUTION CONSTRUCTION STANDARDS

REVISION B DATE MAY 18

CABLE TRENCH LAYOUT
GREEN FIELD SITE
ONE LAYER (1 HV FEEDER AND LV CABLES)

DRAWING No. R59